



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Screened Class E_A / Category 6A Two Connector Permanent Link

FIBRAIN Sp. z o.o.
ul. Wspolna 4a,
35-205 Rzeszow, Poland

Attestation of Conformity No. 110722

This type of Class E_A / Category 6A screened two connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E_A requirements of amendment 2 to 2nd Edition ISO/IEC 11801, amendment 2 to CENELEC EN 50173-1 (Draft FprAB July 2010), and Category 6A requirements of ANSI/TIA-568-C.2. The Compliance Statement is valid for the permanent link in T568B designation connected with RJ 45 plugs from FIBRAIN, P/N XR22C.045, and consisting of the following components:

| | | |
|----------------------|--|---|
| <i>Cable:</i> | <i>Horizontal Cable from FIBRAIN, Qualification Status:</i> | <i>P/N Rapid Series Manufacturer verified</i> |
| <i>Conn. Hardw.:</i> | <i>Keystone Jack from FIBRAIN, Patch Panel from FIBRAIN: Qualification Status:</i> | <i>P/N XR100.450 having PCB Marking R001-9080 Cat.6A P/N XR100.250 having PCB Marking 001-0880 Cat.6A Manufacturer Verified</i> |

Hoersholm, 22nd August 2010

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 22nd August 2010

Poul Villien

Poul Villien
Coordinating Manager